

AMENDMENT NOTICE 1

RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru

The Pacific Community hereby gives notice that the Request for Proposal (RFP 21/057): Supply and delivery of plastic water storage tanks and all tank accessories to Nauru has been amended to take into account the following changes:

Item No.	Bidding Document Reference		Amendment
	Name	Description	
1.	Annex II Terms of Reference RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru B. Tender Specification 2. Plastic water tank storage specification i. Water tanks	The material make-up of the tanks is HDPE (High Density Polyethylene) and shall comply fully with the following Australian and New Zealand Standards, and any other relevant Standards and Compliance Requirements: AS 2070:1999, AS4020:2005, AS/NZS 4766:2006, AS/NZS 4766-2006, ISO 9001-2008 as well as US FDA approved certification.	Delete existing sentence and replace with: The material make-up of the tanks is LLDPE (Linear Low Density Polyethylene), and shall comply fully with the following Australian and New Zealand Standard, AS/NZS 4766:2006, ISO 9001 2008.
2.	Annex II Terms of Reference RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru B. Tender Specification 2. Plastic water tank storage specification ii. List of materials and requirements No. 1 Item Description	AS 2070 1999, AS 4020 2005, AS/NZ 4766 2006, ASNZ 4766 2006, ISO 9001 2008 as well as US FDA approved certification Plastic water tanks 5,300 litres or 1,178 gallons with maximum height of 2,480 mm or 8.14', maximum diameter of 1,800 mm and all tank accessories	Delete existing sentence and replace with: AS/NZ 4766:2006, ISO 9001 2008 Plastic water tanks 5,300 litres or 1,178 gallons with maximum height of 2,480 mm or 8.14', maximum diameter of 1,800 mm and all tank accessories

Item No.	Bidding Document Reference		Amendment
	Name	Description	
3.	Annex II Terms of Reference RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru B. Tender Specification 2. Plastic water tank storage specification ii. List of materials and requirements No. 2 Item Description	AS 2070 1999, AS 4020 2005, AS/NZ 4766 2006, ASNZ 4766 2006, ISO 9001 2008 as well as US FDA approved certification Plastic water tanks 10,200 litres or 2,267 gallons with maximum height of 2,550 mm or 8.3', maximum diameter of 2,450 mm and all tank accessories	Delete existing sentence and replace with: AS/NZ 4766:2006, ISO 9001 2008 Plastic water tanks 10,200 litres or 2,267 gallons with maximum height of 2,550 mm or 8.3', maximum diameter of 2,450 mm and all tank accessories
4	Annex IV Technical Proposal Submission Form RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru Part C Compliance with the technical specifications Item 1 Specification	The material make-up of the tanks is HDPE (High Density Polyethylene) and shall comply fully with the following Australian and New Zealand Standards, and any other relevant Standards and Compliance Requirements: AS 2070:1999, AS4020:2005, AS/NZS 4766:2006, AS/NZS 4766-2006, ISO 9001-2008 as well as US FDA approved certification	Replace this sentence with: The material make-up of the tanks is LLDPE (Linear Low Density Polyethylene), and shall comply fully with the following Australian and New Zealand Standard, AS/NZS 4766:2006, ISO 9001 2008.
5	Annex V Financial Proposal Submission Form RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru No. 1	AS 2070 1999, AS 4020 2005, AS/NZ 4766 2006, ASNZ 4766 2006, ISO 9001 2008 as well as US FDA approved certification Plastic water tanks 5,300 litres or 1,178 gallons with maximum height of 2,480	Delete existing sentence and replace with: AS/NZ 4766:2006, ISO 9001 2008 Plastic water tanks 5,300 litres or 1,178 gallons with maximum height of 2,480 mm or 8.14', maximum diameter of 1,800 mm and all tank accessories

Item No.	Bidding Document Reference		Amendment
	Name	Description	
	Item description	mm or 8.14', maximum diameter of 1,800 mm and all tank accessories	
6	Annex V Financial Proposal Submission Form RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru No. 2 Item description	AS 2070 1999, AS 4020 2005, AS/NZ 4766 2006, ASNZ 4766 2006, ISO 9001 2008 as well as US FDA approved certification Plastic water tanks 10,200 litres or 2,267 gallons with maximum height of 2,550 mm or 8.3', maximum diameter of 2,450 mm and all tank accessories	Delete existing sentence and replace with: AS/NZ 4766:2006, ISO 9001 2008 Plastic water tanks 10,200 litres or 2,267 gallons with maximum height of 2,550 mm or 8.3', maximum diameter of 2,450 mm and all tank accessories
7			See also attached to this Amendment Notice REVISED Annex IV Technical Proposal Submission Form RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru
8			See also attached to this Amendment Notice REVISED Annex V Financial Proposal Submission Form RFP 21-057: Supply and delivery of plastic water storage tanks and all tank accessories to Nauru

Please find on same link provided is the updated financial and technical proposal submission form.