



Paint exterior of existing steel 5,000 U.S
Gallon capacity water tank with 2 coats
primer and 2 coats finishing paint

CHANGE ALL STEEL VERTICAL
SUPPORT OF STEEL LADDER
STEEL ENCLOSURE WITH
1/4 X 2 GALVANIZED FLAT
STEEL FLAT BAR.

CHANGE ALL RUSTED STEEL
HORIZONTAL SUPPORT OF
STEEL LADDER STEEL ENCLOSURE
WITH 1/4 X 2 GALVANIZED FLAT
STEEL FLAT BAR, CLEAN AND REPAINT
THE REST.

CHANGE ALL RUSTED STEEL
STEEL LADDER WITH 1/4 X 2 X 2
GALVANIZED STEEL TUBE , CLEAN
AND REPAINT THE REST.



Existing ladder leading up to existing 5,000 U.S Gallon capacity water tank



Existing ladder leading up to existing 5,000 U.S Gallon capacity water tank

Kayangel Water System

Scope of Work:

1. Supply and install new float switches

Wet Well Tank – 1 piece
(Control low level)



Elevated Tank – 2 pieces
(Control low and high level)



Float Switch Specifications:

Brand: SJE Rhombus, SPDT Type, 120/220Volts,



2. Replace Float switches wires if damage
3. Testing and commissioning of Float Switches